

ATTESTATION OF CONFORMITY

Issued to: EAE Elektrotechnik San. Ve Tic. A.S.
Ikitelli Organize Sanayi
Bölgesi Eski Turgut Özal
Caddesi No 20
34490 Ikitelli - Istanbul
Turkey

For the product: low-voltage switchgear and controlgear assemblies

Trade name: EAE

Type/Model: PanelMaster / E-Kabin S Series

Ratings: $I_{pc\ arc}$ 65 kA at 415 V, t_d 300 ms
 $I_{p\ arc}$ 65 kA at 415 V, t_{arc} 300 ms

Manufactured by: EAE Elektrotechnik San. Ve Tic. A.S.
Ikitelli Organize Sanayi
Bölgesi Eski Turgut Özal
Caddesi No 20
34490 Ikitelli - Istanbul
Turkey

Subject: The performance of testing under conditions of arcing due to internal fault.

Requirements: IEC/TR 61641, ed. 3.0 2014-09

Remarks: -

This Attestation of Conformity is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2191220.01-INC, 9 February, 2016.

The examination has been carried out on single samples of multiple configurations representative of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA

Arnhem, 9 February, 2016

Number: 2191220.01A

DEKRA Certification B.V.

H.R.M. Barends
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed